VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	43 - Coquitlam
School Name:	Montgomery Middle
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes Date of last inspection: 2024-05-02 Date of next inspection: Sep 2024 Date and type of most recent maintenance: May 2024 HVAC Service.
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes Detail: HVAC Maintenance/service
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes Detail (Including filter grade): Merv 10 Dual (as per consultant's recommendation)
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes Detail: Dedicated DDC Mechanical Technologist manage sites through automated control systems, ensuring proper operations of HVAC
Other Relevant Information:	None
District Contact for any Questions:	Name: Romeo Mihailov Phone Number: 604-809-3867 Email: rmihailov@sd43.bc.ca